E MAI CH SUME

MISSISSIPPI STATE DEPARTMENT OF HEALTH 2014 NAY 30 AM 10: 04 BUREAU OF PUBLIC WATER SUPPLY CCR CERTIFICATION

CALENDAR YEAR 2013

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

Advertisement in local paper (attach copy of advertisement) On water bills (attach copy of bill) Email message (MUST Email the message to the address below) Other
Date(s) customers were informed:/ / ,/ /
CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct deliver methods used
Date Mailed/Distributed:/_/
CCR was distributed by Email (MUST Email MSDH a copy) As a URL (Provide URL As an attachment As text within the body of the email message
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
Name of Newspaper: NewTon County APPen
Date Published: <u>05/21/14</u>
CCR was posted in public places. (Attach list of locations) Date Posted: 05/28/14
CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):
HICKORY TOWN HALL
IFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

5 - 29 - 14 Date

Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

May be faxed to: (601)576-7800

May be emailed to: Melanie. Yanklowski@msdh.state.ms.us

A CONTRACTOR SHPILL

2014 MAY 15 PM 12: 35

2013 Annual Drinking Water Quality Report Town of Hickory PWS#: 0510006 May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand and Meridian Upper Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Hickory have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Mayor J.C. Wash at 601-646-2211. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday monthly at 7:00 PM at the Hickory Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Contaminant	Violation	Date	Level	TEST RESU		MCLG	MCL	Likely Source of Contamination
	Y/N	Collected	Detected	# of Samples Exceeding MCL/ACL	Measure -ment			

10. Barium	N	2013	.008	.007008	pį	om	2		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013	1.5	1.3 – 1.5	p	ob	100		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009/11	* .3	0	pį	om	1.3	AL:	AL=1.3 Corrosion of household plumbing systems; erosio natural deposits; leaching wood preservatives	
16. Fluoride	N	2013	.105	.104105	þi	om	4		4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11	* 2	0	bt	do	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Disinfection	n By-	Product	S							
82. TTHM [Total trihalomethanes]	N	2013	4.38	No Range	ppb		0	80 By-product of drinking water chlorination.		
Chlorine	N	2013	1	.27 – 1	mg/l		0 MD	MDRL = 4 Water additive used to control microbes		

^{*} Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Town of Hickory works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

STATE OF MISSISSIPPI

COUNTY OF NEW YOR	- to the formulated Lubo
Personally came before me the undersigned authority, in and for the	County and State aforesaid Luke
Horton, who being by me duly sworn, states on oath that he is the	Publisher of The Newton County
Horton, who being by me duly sworn, states on oath that he is the	1 dollared of 1 to 1 to 1 to 1 to 2

Horton, who being by me duly Appeal, a newspaper published	sworn, states on on in Newton County	oath that he is the Mississippi. A cop	by of which is hereto	attached, has
been made in said paper	times consecu	tively, to-wit:		
			Date 🖰 💛	
For:	Vol. No	No	Date	,20
Town of	Vol. No	No	Date	,20
1 Starter	Vol. No		Date	
	Vol. No.		Date	,20
		ure:	Hat	
		ure:	Sworn to and subsc	ribed before me,
decreased two-tentis of a percentage point over the month, and was eightenn to the first point below the year ago rate of 7.6 percent. Mississippl's non-farm 8,830° in the labor force, oil labor force, oil	this is member at early a composed of about G is graced this in the result of the resu	day of	Notary Public Publicativ	OF MISSISSISSISSISSISSISSISSISSISSISSISSISS
month, and was eightenths of a percentage point below the year age rate of 7.6 percent. Mississippi's non-farm employment increased 4,600 over the month and was 5,500 higher than a was 3,500 foverment and was 3,500 foverment and specific properties.	Nest Ober 16 Ober 16 Ober 16 Ober 16 Ober 16 Ober 17 O			

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to highly you'deput the Quality water resources. We and services we deliver to you every day. Our constant goal is to provide you with a sale and dependable supply of drinking water. We are services we deliver to you every day. Our constant goal is to provide you with a sale and dependable supply of drinking water. We are services we deliver to you every day. Our constant goal is to provide you with a sale and dependable supply of drinking water. We are services the water treatment process and protect our water resources. We are the sale of the services and protect our water services is from wells drawing from the Sparta Sand and Meridian Upper value of the services of the ser

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility water system and is available for viewing upon request. The wells for the determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the well-standard to our public water system and is available for viewing upon request. The well for the well-standard to our public water system and is available for viewing upon request. The well-standard to our public water system and is available for viewing upon request. The well-standard to our public water system and is available for viewing upon request.

If you have any questions about this report or concerning your water utility, please contact Mayor J.C. Wash at 801-646-2211.

Want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regulations of the property of the prop

Scheduled meetings. They are held on the first Tuesday monthly at 7:00 PM at the Hickory Town Hall.

We routinely monitor for constituents in your dinking water according to Peter and State laws. This table below lists all of the monitoring monitoring water contaminants that we detected during for the period of January 1º tel. December 3º 1º 2013. In cases where monitoring water contaminants that we detected during for the period of January 1º tel. December 3º 1º 2013. In cases where monitoring water contaminants that we detected during for the period of January 1º tel. December 3º 1º 2013. In cases where monitoring water travels over the surface of land or underground, it dissolves water travels over the surface of land or underground, it dissolves water travels over the surface of land or underground the presence and the period of land or underground the presence of land or underground the land of land or underground the land of land or underground the land of land or land

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfactant Level (MROL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per kiter (mg/l) - one part per million corresponds to one minute in two years or a single panny in \$10,000. Perts per billion (opb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

000,000.	Violation Y/N	Date Collected	Level Delected	TEST RESI Range of Delecis or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	ikely Source of Contamination
Inorganic	Contam	inants	008	007 - 008	ppm	100	1 :-	Discharge of drilling wastes; gischarge from metal refineries; erosion of natural deposits Discharge from sleel and pulp mills; erosion of natural deposits Corrosion of household
13. Chromium	N	2013	1.5	1.3 - 1.5	ppm	1.3	_	natural deposits: leaching from wood preservatives A Erosion of natural deposits:
16 Fluoride	N	2013	.105	.104105	ppm	-	O AL"	fertilizer and aluminum factories
17 Lead	N	2009/1	2	0				By-product of drinking water
Disinfed	ction By	Produc	4 38	No Range	mg/l	0	60 MDRL = 4	chlorination.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels. [Total Impalomethanes] N 2013 1

Chlorine N 2013 1

*Most recent sample. No sample required for 2013.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are a indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring the systems of any missing samples prior to the end of the compliance period. Trequirements, MSOH now notifies systems of any missing samples prior to the end of the compliance period.

requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated tevels of tead can cause serious health problems, especially for pragnant women and young children. Lead in finite present, elevated tevels of tead can cause serious health problems, especially for pragnant women and young children. Lead in the present of the problems o

overs was resums. Prease contact 001.076.1652 if you wan to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These the presence of drinking water are subject to potential contamination by substances. All drinking water, including bottled water, may reasonably be expected to contain all least small amounts of some contaminants. The presence of contaminants does not accessarily indicate to contain all least small amounts of some contaminants and potential health effects can be necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be necessarily indicate that the water poses a health risk work of information about contaminants. The presence of contaminants are potential health effects can be necessarily indicate that the water poses a health risk work of information about 201426-4781.

outsinest by calling the Environmental Protection Agency's bate Unixing Wester Hottine at 1-800-426-4791.

Some people may be more vulnerable to contaminate in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chembineraby, persons who have undergoing organ transplants, people with HIV/AIDS or other immune system discrete, some elderly, and infants can be particularly at the from infactions. These people should seek advice the immune system discrete, some elderly, and infants can be particularly at the proprietal means to less in the fact of the providers. EPACPC guidelines or appropriate means to less in the fact of the providers. EPACPC guidelines and appropriate means to less in the fact of the providers. EPACPC guidelines or proprietal means to less in the fact of the providers. EPACPC guidelines are providers. EPACPC guidelines or proprietal means to less in the fact of the providers. EPACPC guidelines or proprietation and other microbiological contaminants are available from the Sale Drinking Water Hotine 1-800-426-4791.

The Town of Hickory works around the clock to provide top quality water to every tap. We ask that all our customers help us protect